



REF.: 9/23/99/16854

DATE: 17/10/2023

: الرقم

: التاريخ

TELEFAX MESSAGE

Page 1 of 1

To	Company :	
	Attention:	
	Fax No. :	
	Country :	Amman-Jordan
Subject:	Tender No.(99/2023):Supplying of Outdoor CTs & VTs - Clarifications	

Dear Sir ;

Reference to the offered bid No.(99/2023); for supplying outdoor current and voltage transformers and related to clarification request from bidders, Kindly note the following :

Question	EDCO Reply
Please note that the tender specifications mentions voltage ratio as 33/0.11kV, which is double bushing, as per enclosed drawing, additionally tender specifications request 1.9Un for 30s. Therefore, we assume the primary voltage and secondary voltage should be $33/\sqrt{3}:0.11/\sqrt{3}$ and in this case, VT will be single bushing, hence the enclosed drawing need to be revised to reflect one bushing.	Since the required materials are for metering purposes as mentioned in tender documents, one bushing only is needed in the primary side.

Faithfully Yours,

Director General

Eng. Reem Hamdan

CC:	Meters. Dept./ Supply Dept.		
BANK NAME		L/C No.:	
830878 عمان 11183 - الأردن ☐ / (+962-6) 5331330 / فاكس (+962-6) 5341213 FAX: (+962-6) 5341213 ☎: (+962-6) 5331330 / ☐: 830878 AMMAN 11183 JORDAN			